

**Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department
Periodical Renewal Fire Certificate**

File No: 27254/EGV/MSB/2025

Date: 18/07/2025

Sir/Madam,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Issue of Periodical Renewal Fire Certificate to the existing building of **(Sri Annapurna (EM) High School) Sri Annapurna (EM) High School, D.NO. 17-2-17/1, Alamuru Road, Mandapeta Village & Mandal, East Godavari District.** - Regarding.

Ref: 1. NOC for Occupancy Rc.No: 1205/A2/2013, Dt.22/04/2013
2. Your Application Dt. 10-07-2025

Having satisfied with the reasonable fire safety measures that you have affirmed to have undertaken in your School/College buildings. I hereby grant Periodical Renewal Fire Certificate is valid for a period of One year.

1. **Ensur two exits/two staircases for orderly evacuation of teachers, students and staff in case of any fire incident or emergency.**
2. **Conduct Mock Drill @ twice a year with participation of teachers, students and preferably in presence some of the parents. And take signatures of staff, teachers, parents, student leaders affirming their familiarity with the equipment and its functioning.**
3. **Ensured Electrical Safety by observing the following Precautions:**
 - a. Installation of Miniature Circuit Breakers (MCBs) in all floors.
 - b. No Overloading of power sockets in any Educational Building.
 - c. 10 years old wiring to be changed, especially where high power consuming appliances such as Air conditioners, Electrical/Mechanical/Computer labs, High-tech labs, etc., are used.
 - d. Grounding/Earthing shall be done.
 - e. Lightening conductors may be provided for high-rise buildings exceeding 5 floors.
 - f. No High Tension Lines should run inside or in close proximity (< 6 meters) to any Educational institution buildings.
 - g. No charging for EV vechiles @ cellars of School/College buildings.

Let the above be tested and certified by any electrical Engineer without regard to any Jurisdiction under employment of Government of Andhra Pradesh once a year.


For Sri Annapurna Educational Trust

VSN Chowdary
CHAIRMAN

M. J. P. Kumari
PRINCIPAL
SRI ANNAPURNA (E.M.) SCHOOL
MANDAPETA-533 308
Dr. B.R. Ambedkar Konaseema District. (A.P.)

4. As the ensuring safety is a continuous learning process, we will advise from time to time, practical , modern , reliable but not too hard or that require major modifications to your building structure. And you shall undertake to observe these precautions to enhance fire safety.
5. Therefore, this building meets the **"reasonable fire safety criteria"** as envisaged in NBC and hence the Renewal Fire NOC is issued.
6. As a Policy, no retrospective application of rules shall be made for building as long as they comply with that NOC requirements till the life of the building.
7. Any clarifications, you are welcome to meet the DG, Fire Services (9441236448) without appointment in his office as ensuring fire safety with better and affordable technology is a continuous learning and collaborative endeavour.(for school fire safety mock drill, visit https://www.youtube.com/watch?v=OW-oyYEAT_4)

Your Sincerely,



Director General

State Disaster Response & Fire Services
Andhra Pradesh, Vijayawada.

To

The Management of Sri Annapurna (EM) High School, Sri Annapurna (EM) High School,
D.NO. 17-2-17/1, Alamuru Road, Mandapeta Village & Mandal, East Godavari District.

Copy to the District Educational Officer, Concerned.

Copy to the Secretary Board of Intermediate Education, Andhra Pradesh, Vijayawada

For Sri Annapurna Educational Trust


CHAIRMAN


PRINCIPAL

SRI ANNAPURNA (E.M.) SCHOOL
MANDAPETA-533 308
Dr. B.R. Ambedkar Konaseema District. (A.P.)